

Swimming Pool Disinfection Requirements

Facility Type	pH Level	Free Chlorine Residual	Bromine
Swimming Pool	Less than or equal to 7.8	0.6 to 5.0 mg/l	
Swimming Pool	7.8 to 8.2	1.5 to 5.0 mg/l	
Swimming Pool using Bromine	7.2 to 7.8		1.5 to 6.0 mg/l
Spa Pool or Hot Tub	7.2 to 7.8	1.5 to 5.0 mg/l	3.0 to 6.0 mg/l